# Radon mitigation by soil depressurisation case study: radon concentration and pressure field extension monitoring in a pilot house in Spain

Marta Fuente<sup>1,2,3</sup>, Daniel Rábago<sup>4</sup>, Jamie Goggins<sup>2,3</sup>, Ismael Fuente<sup>4</sup>, Carlos Sainz<sup>4</sup>, Mark Foley<sup>1\*</sup>

<sup>1</sup>School of Physics, National University of Ireland Galway, Ireland

<sup>2</sup> Civil Engineering, School of Engineering, National University of Ireland Galway, Ireland

<sup>3</sup> Centre for Marine and Renewable Energy (MaREI), Ryan Institute, National University of Ireland Galway, Ireland

- <sup>4</sup> Radon group, University of Cantabria, Spain
- \* Corresponding author

School of Physics, National University of Ireland Galway (NUIG). University Road, Galway, Ireland

E-mail address:

mark.foley@nuigalway.ie (Mark Foley)

m.fuentelastra1@nuigalway.ie (Marta Fuente)



# 1 Highlights

2	•	Active and passive soil depressurisation (SD) ability was studied in a pilot house.
3	•	Radon concentration and pressure field extension (PFE) under slab were monitored.
4	•	Radon behaviour was analysed under the influence of atmospheric parameters.
5	•	Pressure drop with distance was found proportional to depressurisation under slab.
6	•	Over 85% radon reduction was achieved for active and passive SD.

## 1 Radon mitigation by soil depressurisation case study: radon concentration

## 2 and pressure field extension monitoring in a pilot house in Spain

- 3 Marta Fuente<sup>1,2,3</sup>, Daniel Rábago<sup>4</sup>, Jamie Goggins<sup>2,3</sup>, Ismael Fuente<sup>4</sup>, Carlos Sainz<sup>4</sup>, Mark
- 4 Foley<sup>1\*</sup>
- <sup>5</sup> <sup>1</sup>School of Physics, National University of Ireland Galway, Ireland
- <sup>6</sup> <sup>2</sup> Civil Engineering, School of Engineering, National University of Ireland Galway, Ireland
- <sup>7</sup> <sup>3</sup>Centre for Marine and Renewable Energy (MaREI), Ryan Institute, National University of
- 8 Ireland Galway, Ireland
- 9 <sup>4</sup> Radon group, University of Cantabria, Spain
- 10 \* Corresponding author
- 11 E-mail address: <u>mark.foley@nuigalway.ie</u>, <u>m.fuentelastra1@nuigalway.ie</u>

## 12 Abstract

A one-year monitoring study was conducted in a pilot house with high radon levels to 13 investigate the ability and efficiency of radon mitigation by soil depressurisation (SD) both 14 active and passive. The study included monitoring of radon concentration, pressure field 15 extension (PFE) under the slab and some atmospheric parameters for different testing 16 phases. Periods in which the house remained closed to foster radon accumulation were 17 alternated with phases of active and passive soil depressurisation under different 18 conditions. The behaviour of the radon concentration in the pilot house was analysed along 19 with the influence of atmospheric variables, significant correlations were found for the 20 radon concentration with atmospheric pressure, outdoor temperature and wind. From the 21

PFE analysis it was proven that the pressure drop with distance from the suction point of the SD system is proportional to the depressurisation generated. It was also found that the permeability characterisation of the pilot house agrees with the literature about granular fill materials characterisation for radon SD systems across Europe. Radon reductions in excess of 85% were achieved for the different testing phases in all cases. Finally, from the results it was stated that a fan power of 20 W is sufficient to ensure radon reductions over 85% for dwellings with similar aggregate layer and soil permeability.

29 Keywords: Radon mitigation, Soil Depressurisation, Pressure field extension, Permeability



30

## 31 1. Introduction

Radon (<sup>222</sup>Rn) is a colourless, odourless, radioactive gas formed in the ground by the 32 radioactive decay of uranium (<sup>238</sup>U), which is present in all rocks and soils of the Earth's 33 crust. With a half-life of 3.8 days together with its noble gas condition, radon can move 34 through interconnected pores in the soil, reach the Earth's surface and penetrate into 35 buildings. Radon is the greatest natural source of exposure to ionising radiation for the 36 general public and it is also the leading cause of lung cancer after smoking, as stated by the 37 38 World Health Organisation (WHO, 2009). Poor ventilation conditions, gaps or cracks in the construction systems favour the accumulation of radon inside buildings, leading to health 39 risks related to the inhalation of the radon decay products. 9% of deaths from lung cancer 40

41 per year are attributable to residential radon exposure in the European Union, which
42 accounts for more than 20,000 deaths each year (Darby et al., 2004; WHO, 2018).

There are various prevention and mitigation measures that might be considered to minimise indoor radon concentration, in order to address the radon problem both in new and existing buildings. Radon protection strategies include reduction of radon entry by sealing of surfaces, barriers or membranes, soil depressurisation (SD) techniques to reverse the air pressure differences between the indoor occupied space and the soil underneath the building, and ventilation of spaces to dilute indoor radon concentration with external air (Long et al., 2013; Jiránek, 2014; WHO, 2018).

50 The active and passive SD techniques have proven to be the most effective strategy for indoor radon prevention and mitigation. SD systems include three basic components: a 51 suction point, ideally located in a continuous and uniform permeable aggregate layer under 52 53 the slab, an exhaust pipe to extract the soil gas and a means of extraction, which can be a 54 mechanical fan in case of forced extraction or a cowl for passive depressurisation using the 55 wind force. The suction point is normally a sump placed under the slab or on a side of the building, connected to a permeable aggregate layer, but perforated pipes beneath the 56 existing floors can be an alternative to sumps (DELG, 2002; Abdelouhab et al., 2010; Long et 57 al., 2013). 58

Previous works discuss the importance of the aggregate layer in the design of SD systems for radon mitigation. The impact of the granular fill materials permeability of such aggregate layer and the soil permeability beneath and surrounding the building on the SD effectiveness has been investigated and permeability characterisation of aggregates within the European context conducted (Hung et al, 2018a; 2018b; Fuente et al., 2019). But there is

a lack of evidence in testing efficiency of SD techniques in relation with the pressure
distribution in actual buildings with elevated radon concentration where radon reduction
can be quantified with confidence.

This paper outlines a case study on radon mitigation by soil depressurisation in a real building. A one-year monitoring study was conducted in a pilot house with very high radon levels to investigate the ability and efficiency of active and passive SD. The work includes the behaviour analysis of the radon concentration inside the experimental building. Also, it presents the analysis of the SD effectiveness, looking at the pressure distribution induced under the building slab, in relation to the permeability characterisation of the aggregate layer beneath the slab, and the achievable radon reduction in such conditions.

## 74 2. Materials and methods

### 75 2.1 Pilot house: location and design

76 The pilot house chosen for the case study is located in Saelices el Chico, Salamanca (Spain) within the land of a former uranium mine managed by the company ENUSA Industrias 77 Avanzadas S.A. (see Figure 1) now under reclamation activities. The location of the 78 79 experimental house was selected due to the high radon exhalation rate and the high radium 80 content in the soil of the area, which would provide high radon levels accumulated inside the building. An average radium concentration of 1600 Bg/kg was quantified from different 81 soil samples taken onsite, this value is 40 times in excess of the average world-wide 82 concentration, approximately 40 Bq/kg (Frutos et al., 2011). 83

The experimental house was designed to reproduce a space large enough to be representative of a room in a typical dwelling house. It consists of two storeys, a partially

below grade so-called basement and a ground floor connected by a standard door. The
dimensions of the rooms are 5 x 5 m<sup>2</sup> (see Figure 2). There are two windows at the ground
floor level, one in the front wall next to the main door and another one in the opposite wall.
The front wall of the house is facing the North.



90

Figure 1. Map of Spain and plan of the mining facilities indicating the location of the pilothouse and a recent picture of the building.

In 2006 when the pilot house was built for a different study, several mitigation measures were investigated (Frutos 2009). As a result, there are two soil depressurisation systems installed in the house. Both SD systems consist of a 1 m<sup>2</sup> and 0.5 m deep sump and an exhausting pipe, one system is located in the centre of the experimental house with the sump placed in the aggregate layer below the concrete slab and the other system is placed on a side of the house (see Figure 2). 99 Materials used for the construction of the house were according the Spanish building 100 practices, a 15 cm thick aggregate layer was placed below a 10 cm thick concrete slab. 101 Standard clay bricks were used for the walls and conventional perforated clay bricks to build 102 the sumps of the SD systems (Frutos et al. 2011).





## 106 2.2 Monitoring system

To continuously monitor radon concentration several active radon monitors were used, including the Radon Scout (SARAD GmbH), Radon Scout Home (SARAD GmbH) and AlphaE (Bertin Instruments) detectors. Performance of the radon monitors used in the experiment at the pilot house was tested previously in a purpose-built radon chamber (Fuente et al., 2018). Radon concentration was recorded in the basement and in the ground floor.

112 For some measurement periods, the radon monitors used were contaminated due to the 113 high radon exposure levels at the pilot house. These monitors were then replaced. There were also some problems due to memory of the devices in some cases, so there is radondata missing for some of the testing phases.

116 A pressure sensor system was installed to monitor the distribution of pressure under the slab of the house. The pressure system was specifically developed for this experiment at the 117 118 pilot house in collaboration with a research group of the ITEFI-CSIC, Madrid (Spain). It is an 119 acquisition system designed with segmented architecture and capacity up to 15 pressure sensors. It consists of an adaptor board for the pressure sensor units and contains a series of 120 121 Honeywell pressure sensors (HSCDRRD006MDSA3 model, operating pressure ± 6 mbar, 122 accuracy 0.25%) with SPI communication. The connections between the units use Ethernet cables connected in parallel and the adaptor board needs to be connected to a PC by an 123 input/output USB card type Lab Jack U3. The actual system installed in the house for this 124 experiment consists of a total of 8 pressure sensor units. There are 5 of them distributed 125 along the basement area in different holes drilled through the concrete slab to measure 126 127 pressure difference in the aggregate layer under the slab and the inhabited volume of the basement, at distances d= 1, 2 and 2.4 m from the central sump. The remaining 3 pressure 128 sensors are placed at the sump and pipe of the central SD system and at room level for 129 reference. 130

To record atmospheric conditions locally at the house site, a local weather station (PCE-FWS20, PCE Instruments) was installed on the rooftop. Variables recorded were wind velocity, outdoor temperature, atmospheric pressure, relative humidity percentage and accumulated rain. Both the pressure sensor system and the weather station are remotely accessible which facilitates data collection.

136 2.3 Experimental methodology

The initial monitoring plan was alternating testing phases of SD performance (active or passive) with periods in which the house remained completely closed, in order to record radon increase and reduction over the different phases along with the pressure field extension induced under the slab, hereinafter referred as PFE.

The monitoring study commenced in June 2018 with a first phase of the house closed to foster accumulation of radon gas. All testing phases with this setting, in which the house remains closed and the pipes of the SD systems capped to foster radon accumulation in the building, will be henceforth referred as closed periods. After the first closed period (phase 1), a phase 2 involved passive SD performance evaluation. Then a subsequent series of closed periods followed by active SD performance was conducted up to 9 phases, with different active SD settings, ending in April 2019.

Only the central SD system was used for the investigation of the soil depressurisation during 148 149 the SD testing phases. A rotating cowl was used for the passive SD operation and for the 150 active SD performance, a mechanical fan (RP145i, RadonAway with 80 W max) was installed 151 in the central SD system pipe. The mechanical fan was modified by adding a potentiometer to control the extraction airflow, which in terms of velocity ranges from 0 to 4 m/s. A hot 152 wire anemometer (Testo 440, measuring range 0 to 30 m/s, accuracy  $\pm$ (0.3 m/s + 4% of mv) 153 and resolution 0.01 m/s) was used to measure extraction velocity of the mechanical fan. A 154 155 schema of the experimental house settings for the different phases is shown in Figure 3.



156

Figure 3. Schema of the pilot house for the closed periods, active SD and passive SD testing phases. Section view of the experimental house shows the pressure sensors system in the basement (same for all phases), the mechanical fan installed on the central pipe (for the active SD performance) and the top of the exhaust pipe in the house rooftop, with a cap, a rotating cowl or opened, depending on the testing phase.

162 The duration of the different phases varied, depending on the access to the site and 163 technical problems experienced with the sensors or the power supply. The monitoring study 164 was stopped at some times and later resumed.

From February 2019, a stage of the monitoring study focused on the investigation of the mechanical fan extraction impact on the SD effectiveness was conducted. It consisted of short periods (1-2 weeks) of active SD followed by closed periods, gradually increasing the mechanical fan extraction for the SD performance by controlling the airflow rate.

169 A summary of the testing phases including dates and incidents are presented in Table 1.

Phase	Description	Dates			
1	Closed period	25/06/2018 – 26/07/2018			
2	Passive SD	26/07/2018 – end of August			
No meas	urements (issues related with t	the pressure sensors)			
3	Closed period	10/10/2018 – 13/11/2018			
4	Active SD ( $v_{ext}$ = 0 – 4 m/s)	13/11/2018 – 16/11/2018			
No meas	No measurements (issues related to power supply in the house)				
5	Closed period	13/12/2018 – 19/02/2019			
6	Active SD ( $v_{ext}$ = 1.5 m/s)	19/02/2019 - 06/03/2019			
7	Closed period	06/03/2019 – 14/03/2019			
8	Active SD ( $v_{ext}$ = 2 m/s)	14/03/2019 – 02/04/2019			
9	Closed period	02/04/2019 - 30/04/2019			

170 Table 1. Summary of testing phases at the pilot house.

171

Radon levels were monitored continuously, but also, passive radon detectors were used for
some testing periods. However, due to the high radon concentration the passive track
etched detectors were saturated in the most cases.

## 175 **3. Radon concentration behaviour in the pilot house**

There is a long term record of the radon concentration fluctuations in the experimental house measured during the different testing phases. Before looking at the radon reductions generated as a result of the soil depressurisation, it is important to try to understand the natural behaviour of the radon concentration inside the house. To do so, the closed testing periods when there were no mitigation measures in operation and the house remainedclosed with the exhaust pipes of the SD systems capped are analysed.

Indoor radon levels in the experimental house depend on three features: the radon source,
the entry rate and the air exchange between the building and the outdoor air, all of which,
in turn, depend on many other variables and especially atmospheric conditions.

The radon source is constituted by the soil beneath and surrounding the house, which contains high radium levels. Therefore, it is expected to find higher radon levels in the basement, which is partially below grade and in direct contact with the soil, than in the ground floor. An overview of the radon levels recorded is presented in Figure 4.



189

Figure 4. Radon concentration recorded in the basement and ground floor of the pilot
house. The solid line indicates the closed testing periods and the dashed line (shaded areas)
indicates the periods of SD performance.

An average radon concentration of 55 kBq/m<sup>3</sup> is found in the basement for the closed house conditions, while for the ground floor there is an average radon concentration of 26 kBq/m<sup>3</sup> under the same house settings. Both values are obtained from the radon records available

during the closed testing periods. The average radon concentration values from the initial 196 study conducted in 2006 are 40 kBq/m<sup>3</sup> for the basement and 7 kBq/m<sup>3</sup> for the ground floor. 197 These values were obtained from a three month measurement period (January-April) in 198 which the experimental house remained closed building up the radon concentration, before 199 200 the installation of any mitigation measures (Frutos et al., 2011). The difference may be 201 related to the deterioration of the basement slab associated with thermal dilation or other 202 analogous phenomenon, therefore leading to the formation of new cracks or radon 203 pathways.

The concentration ratio between floors found for the closed house testing configuration is 204 approximately two, which means that the concentration recorded in the basement is 205 approximately double the concentration in the ground floor. This result is according to 206 207 expectation, as the basement is in direct contact with the soil and the main radon gas entry is through gaps or cracks in the foundation, while the radon in the ground floor comes from 208 209 the radon in the basement. The infiltration through the main door and the windows could 210 be considered as a source of radon gas, but the outdoor air radon concentration at the site is much lower, approximately 300 Bq/m<sup>3</sup>. Then, assuming that radon in the ground floor 211 comes only from the basement, the lower radon concentration in the ground floor is 212 explained by the radioactive decay and the exchange of outdoor air through infiltration. 213

## 214 3.1 Radon behaviour and atmospheric parameters

Fluctuations of radon concentration are daily and seasonal, and they are related to atmospheric conditions and the air exchange between the building and the outdoor air. There is also a seasonal component related to the outdoor temperature changes and the associated atmospheric pressure variations that directly affects radon entry in the building
(Nero et al., 1990; Scivyer et al., 1998).

The air exchange rate in the experimental house reaches its minimum value during the closed testing periods, as there is no ventilation mechanism. Thus, the radon levels in the house basically depend on the atmospheric conditions, which determine the soil gas pressure-driven flow from the ground into the building.

224 The differences between indoor and outdoor temperature in a building can generate a 225 pressure gradient due to the Stack effect, leading to an increase of the soil gas flow from the 226 ground into the basement through the existing entry routes. However, the pressure 227 gradient created due to temperature differences is small compared to the caused by other parameters. The wind effect can generate a pressure gradient too, due to the pressure 228 229 changes and suction generated in the walls, which can modify the indoor pressure relative 230 to that in the ground. But also, the wind causes the opposite effect as it fosters ventilation 231 through infiltration that lower the radon levels (Burke et al., 2010; Baskaran, 2016).

Multiple atmospheric conditions influence radon concentrations and it is possible to find correlations between the trends in radon concentration and atmospheric variables (Schubert et al., 2018; Garcia-Tobar, 2019). The radon concentration trends as a function of the different atmospheric parameters recorded were analysed for the closed testing periods. Selected measurement periods where statistically significant correlation was found between the atmospheric variables and radon levels in the pilot house are presented in Figure 5.

Theoretically, pressure variation inside a dwelling is almost simultaneous with atmospheric pressure changes, but pressure changes in the soil pores beneath the building reach the

241 atmospheric pressure values with a time delay that depends on the soil characteristics (e.g. 242 porosity). Thus, there is a pressure gradient generated between the soil and inside the building that leads to an increase of the soil gas airflow into the building (Frutos, 2009). 243 From the analysis of the experimental data recorded, a negative correlation is found 244 245 between the atmospheric pressure and radon levels, which is consistent with results from other investigations (Mentes et al., 2015). Figure 5a, depicts radon concentration decreasing 246 with the increase of the atmospheric pressure with a time delay, Pearson's correlation 247 coefficient found for this case is r = -0.44 with a 95% confidence level. 248



Figure 5. Radon concentration recorded in the basement and ground floor of the pilot house along with atmospheric variables, a) atmospheric pressure, b) outdoor temperature and c) wind velocity, for different time periods while the house was closed. Pearson's correlation coefficient between radon concentration in the basement and the corresponding atmospheric variable is indicated.

From the analysis of the data recorded at the experimental house, a positive correlation between outdoor temperature and radon concentration is found at a daily scale, agreeing with previous studies (Mentes et al., 2015; Schubert et al., 2018). From Figure 5b data, a Pearson's correlation coefficient of r = 0.44 with a 95% confidence level is obtained.

A negative correlation between the radon concentration and the wind was found, as wind velocity increases the radon level decreases as observed in Figure 5c. For this case an r = -0.59 Pearson's correlation coefficient is obtained with 95% confidence level. This result is also consistent with the literature (Riley at al., 1996; Schubert et al., 2018). No significant correlation with radon levels was found for the other two atmospheric parameters monitored in the study, relative humidity percentage and accumulated rain.

Looking at diurnal radon fluctuations, apart from the difference in the radon concentration levels from the basement and ground floor, the radon concentration records are in some cases temporally shifted one from the other. The explanation for this fact, considering the concentration in the basement as the reference, is that the radon in the ground floor comes from the basement and the exchange between floors takes a few hours, causing a time delay in the radon concentration.

This case study was focused on the impact of the soil depressurisation, so further investigation extended in time would be required to understand the radon behaviour in detail at the pilot house, as a function of all the atmospheric parameters and their time variations.

275 4. Soil Depressurisation effectiveness analysis

The distribution of the pressure induced under the slab as a consequence of the soil depressurisation system performance and radon reduction are analysed below.

## 278 4.1 Pressure Field Extension

The pressure distribution under the pilot house was studied for different depressurisation 279 280 induced at the central sump of the SD system, both by active and passive performance of the system. Prior to the depressurisation analysis, it was found that the pressure difference 281 between the indoor air and the measurement points under the slab fluctuates around 0 Pa 282 283 for the closed testing periods when there is no SD in operation. During the passive SD 284 testing period, the pressure induced under the slab as a consequence of the wind force reached levels of -20 Pa, an example of the passive depressurisation in relation to the wind 285 velocity is shown in Figure 6. 286



287

Figure 6. Hourly averaged pressure induced under the slab at the sump and the different measurement points with distances indicated from the central pipe along with hourly averaged wind velocity recorded at the site.

The analysis of the pressure data recorded under the slab for the different testing phases at distances d= 1, 2 and 2.4 m from the suction point, using the centre of the sump as the reference, leads to obtain the rate of pressure drop with distance across the slab, which is also related to the depressurisation generated (see Figure 7).



#### 295

Figure 7. Pressure drop with distance against pressure induced at the sump. Dots represent the experimental data obtained from pressure records at distances d= 1, 2 and 2.4 m from the sump, both for active and passive SD testing phases. The dashed line is the linear trend obtained from all the experimental data, with a coefficient of determination  $R^2=0.95$ .

Figure 7 shows that the pressure drop with distance results are consistent for the measurements recorded at the different distances d= 1, 2 and 2.4 m from the suction point. The trend of the pressure drop with distance is linear with the depressurisation under the slab, therefore the lower the pressure induced under the slab, the higher the pressure drop with the distance. However, it was found a quite homogenous PFE, not exceeding 1 Pa/m pressure drop rate with distance for the highest depressurisation tested, induced by the highest extraction airflow rate permitted by the fan during the active SD operation. Results of the pressure induced under the slab are presented in Figure 8 as a function of the extraction velocity in the exhaust pipe, for the active SD operation by means of the mechanical fan (a) and for passive SD operation by means of a rotating cowl (b).



Figure 8. (a) Pressure induced under the slab against the extraction velocity of the mechanical fan for the different measurement points at different distances from the suction point. (b) Pressure induced at the sump under the slab against the wind velocity.

Results from the passive SD operation show a lower depressurisation induced at the sump by the wind velocity compared to depressurisation generated as a result of the active SD operation using a mechanical fan. The highest depressurisation under the slab recorded during the passive SD operation, induced by the wind force using a rotating cowl, is -22 Pa and it corresponds to wind velocities up to 8 m/s. However, the highest depressurisation recorded under the slab during the active SD operation is around -250 Pa, induced by the highest extraction airflow rate of the mechanical fan equivalent to 4 m/s.

Abdelouhab et al. (2010) conducted a study of this kind in France at the MARIA (Mechanized house for Advanced Research on Indoor Air) experimental house, built with a 40 cm thick aggregate layer beneath the slab and two sumps, one centred and another decentred placed on the aggregate layer. They calculated two behaviour laws to relate the extraction airflow *Q* with the pressure difference induced between the aggregate layer and the inhabited volume  $\Delta P$  for the natural and mechanical extraction. A similar behaviour law is obtained from the active SD experimental data of the monitoring study at the pilot house (see Figure 9) but in this case it is clear that the extraction airflow needed to generate the same pressure difference is lower compared to the MARIA house.



Figure 9. Extraction airflow through the central exhaust pipe as function of the pressure difference generated between the aggregate layer under the slab and the inhabited volume of the basement. Dots represent the experimental data for the active SD (purple) and passive SD (green), the dashed lines are the trends obtained from the experimental data and the solid lines represent the law relating extraction airflow with depressurisation for active and passive SD from Abdelouhab et al. (2010).

From Figure 9 it is observed that the behaviour law differs for the active and passive SD operation in Abdelouhab et al. (2010), agreeing with the experimental results found here. Although for the pilot house the difference between the behaviour of active and passive SD is significantly different.

According to the results, the permeability characterisation of the aggregate layer under the slab seems to be different from the results of the active and passive SD operation. But it should be taken into account that the extraction airflow rate during the active SD is measured in the exhaust pipe right under the mechanical fan with a hot wire anemometer. As for the passive SD, the wind velocity is recorded by a weather station at the experimental house rooftop and it can differ from the effective extraction airflow at the exhausting pipe.

Hung et al. (2019) studied the permeability characteristics of Irish aggregates used in construction for the aggregate layer below the slab in relation to its depressurisation ability for radon mitigation. Among other results, the work presents pressure difference generated as function of the extraction airflow for different Irish aggregate materials thickness. Although the experiment setup is different, results can be comparable to the outcomes of the monitoring study at the pilot house (see Figure 10).



Figure 10. Pressure induced under the slab against extraction airflow through the central exhaust pipe, along with some results from the work of Hung et al. (2019) for the pressure difference obtained through different layers of T2 Perm aggregate material as function of the extraction airflow. Dots represent the experimental data for the active SD in purple and passive SD in green, and the results from Hung et al. (2019) in grey. The dashed lines are the trends obtained for the experimental data.

From Figure 10 it can be seen that at extraction airflow rates below 100 m<sup>3</sup>/h, the 360 experimental data for the passive SD testing at the pilot house matches the results from 361 362 Hung et al. (2019) for the permeability study of the Irish T2 Perm aggregate material. This means that the permeability characterisation of the aggregate layer under the slab in the 363 pilot house, based on the passive SD testing results, is similar to a layer of 30 to 60 cm of 364 365 Irish T2 Perm aggregate material. This result also agrees with the outcomes from previous work published on the benchmarking of granular fill materials in the European context 366 (Fuente et al. 2019). 367

The radon reductions obtained for the different testing phases are summarised in Table 2, relative to the average radon concentration in the basement and ground floor calculated from the closed testing phases. It should be emphasised that the outdoor radon concentration in the area surrounding the pilot house is very high, approximately 300 Bq/m<sup>3</sup>, while the average outdoor radon concentration globally is between 5 – 15 Bq/m<sup>3</sup> (WHO, 2016).

In all cases the radon reductions obtained are over 85%, and the highest reduction is found for the testing phase 4 reaching a radon concentration in the ground floor of 328 Bq/m<sup>3</sup>, which is comparable to the outdoor radon concentration at the site, and a radon concentration of 662 Bq/m<sup>3</sup> in the basement. During phase 4 the mechanical fan was tested varying the extraction airflow and up to the highest power permitted (80 W).

Table 2. Radon concentration  $C_{Rn}$  found in the basement and ground floor for the SD testing phases indicated and radon reduction, respect to the average radon levels for the closed periods.

	<i>C</i> <sub>Rn</sub> (Bq/m <sup>3</sup> )		Radon reduction	
	Basement	Ground Floor	Basement	Ground
				Floor
Average closed	54625	26421		
Phase 2: passive SD	7417	-	86%	-
Phase 4: active SD	662	328	99%	99%
(v <sub>ext</sub> = 0 - 4 m/s)			/ -	/ -

2276	3680	91%	86%
3320	3089	5470	8076
2701	2270	02%	01%
5701	2279	93%	91%
	3326 3701	<ul><li>3326</li><li>3689</li><li>3701</li><li>2279</li></ul>	3326368994%3701227993%

383

From phase 6 experimental results, it can be highlighted that a 30 W mechanical fan, which is the equivalent power for the extraction airflow used during testing phase 6, is sufficient to reach radon reductions up to 94% in the basement and 86% in the ground floor in a house of these permeability characteristics. In terms of pressure induced under the slab, the average value at the sump recorded for testing phase 6 is -55 Pa.

389 Although it depends on the atmospheric conditions (mainly wind and temperature) and the 390 occupant behaviour, the typical pressure difference found between indoors and the soil in a 391 dwelling oscillates between 0 to 5 Pa. Thus, the depressurisation system should be designed 392 to induce at least -6 Pa in every point of the slab area (Fowler et al., 1991; Broadhead, 2018; Dumais, 2018). Looking at Figure 8a, it can be observed that such pressure is obtained for 393 394 extraction velocities below 1 m/s that correspond to 20 W power of the mechanical fan. 395 Therefore, it could be stated that a 20 W mechanical fan is sufficient to achieve an optimum 396 soil depressurisation reaching radon reductions above 85% for dwellings with similar 397 permeability characteristics to the experimental house studied here.

### 398 **5. Conclusions**

A monitoring study was conducted in a pilot house with high radon levels to investigate the ability and efficiency of radon mitigation by soil depressurisation (SD) both active and

passive. The study was motivated by the need to quantify SD effectiveness in terms of
pressure field extension and also quantify significant radon reductions.

The testing plan consisted of different testing phases, alternating closed periods of the house to foster radon accumulation in the experimental house with SD operation phases. The variables were monitored over the different testing periods were radon concentration in the basement and ground floor of the house, pressure field extension under the slab and atmospheric parameters such as wind velocity, outdoor temperature, atmospheric pressure, relative humidity percentage and accumulated rain.

Radon concentration behaviour was analysed for the closed testing periods, an average radon concentration of 55 kBq/m<sup>3</sup> was found in the basement, while for the ground floor there is an average radon concentration of 26 kBq/m<sup>3</sup>. Atmospheric variables influence on the radon behaviour in the house was also studied, finding significant negative correlations between atmospheric pressure and wind velocity with the radon concentration in the house, and a positive correlation with the temperature.

From the analysis of the pressure distribution under the slab it was proven that the pressure drop with distance from the suction point of the SD system is linear with the depressurisation generated under the slab. Still, it was found that the distribution of the pressure under the slab in the pilot house is quite homogeneous, not exceeding 1 Pa/m pressure drop with distance for the highest depressurisation generated under the slab by active SD.

Results from the passive SD operation show a lower depressurisation induced at the sump
by the wind velocity, besides, it is not constant, compared to depressurisation generated
because of the active SD operation using a mechanical fan. However, based on the results

analysis for the passive SD operation it was found that the permeability characterisation of
the pilot house agrees with previous works published on the characterisation of granular fill
materials for radon soil depressurisation systems across Europe.

Finally, radon reductions in excess of 85% were achieved for the different testing phases in all cases. Based on the radon reduction results associated with the depressurisation generated under the slab as function of the extraction airflow for the active SD conditions considered, it is found that 20 W power for a mechanical fan is sufficient to achieve an optimum soil depressurisation reaching radon reductions above 85%.

To summarise, the case study presented contributes to the specification for optimum soil depressurisation systems performance and the findings encountered have applicability within similar building type dwellings with comparable aggregate layer permeability characteristics within the European context.

## 436 Authors' contributions

437 Mark Foley, Jamie Goggins, Carlos Sainz and Marta Fuente contributed to the initial research 438 plan and the conception of the monitoring study. Marta Fuente, Carlos Sainz, Ismael Fuente 439 and Daniel Rábago also evaluated and reviewed the testing plan. The experimental 440 development of the study was conducted by Marta Fuente and Daniel Rábago with the help 441 from the radon group technical staff (Enrique Fernández, Jorge Quindós and Luis Quindós) and the support of ENUSA Industrias Avanzadas S.A.. Marta Fuente processed the 442 experimental data, analysed the results with the help from Daniel Rábago and wrote the 443 manuscript. Mark Foley, Jamie Goggins, Ismael Fuente and Carlos Sainz reviewed and edited 444 445 the manuscript for the final version. All authors read and approved the final manuscript.

### 446 Acknowledgments

This research was supported by the OPTI-SDS project carried out at the National University 447 448 of Ireland Galway in collaboration with University of Cantabria, Spain. The OPTI-SDS project is funded by the Irish Environmental Protection Agency (EPA) [project code 2015-HW-MS-5]. 449 The work was performed at the ENUSA Industrias Avanzadas S.A. facilities in Spain, thanks 450 451 to the collaboration with the radon group at University of Cantabria. The authors would like to acknowledge ENUSA Industrias Avanzadas S.A. for the support and help while conducting 452 453 the experiment and the technical staff of the radon group for their work on the experimental development of the study. 454

#### 455 **References**

Abdelouhab, M., Collignan, B., Allard, F. (2010). 'Experimental study on passive Soil
Depressurisation System to prevent soil gaseous pollutants into building'. Building and
Environment, 45, 2400-2406. doi:10.1016/j.buildenv.2010.05.001

Baskaran, M., Radon: A Tracer for Geological, Geophysical and Geochemical Studies,
Springer International Publishing, January 2016. <u>10.1007/978-3-319-21329-3</u>

Broadhead, B. (2018). Radon Mitigation in the US. WPB-Radon Inc. At ROOMS (Radon
Outcomes on Mitigation Solutions) conference (27<sup>th</sup>-28<sup>th</sup> September 2018, Lugano,
Switerland). SUPSI.

Burke, O., Long, S., Murphy, P., Organo, C., Fenton, D., Colgan, P.A. (2010). 'Estimation of
seasonal correction factors through Fourier decomposition analysis – a new model for
indoor radon levels in Irish homes'. Journal of Radiological Protection, 30, 433-443.
doi:10.1088/0952-4746/30/3/002

Darby, S., Hill, D., Auvinen, A., Barros-Dios, J. M., Baysson, H., Bochicchio, F., ... Doll, R. 468 (2004). 'Radon in homes and risk of lung cancer: collaborative analysis of individual data 469 from studies'. 470 13 European case-control BMJ, 330 (7485), 223. 471 https://doi.org/10.1136/bmj.38308.477650.63

472 DELG. Radon in existing buildings. Corrective Options. Technical report, Department of the
473 Environment and Local Government, Stationery Office, Dublin, 2002.

Dumais, C. (2018). The Canadian approach to Radon Mitigation and Design. Radonwest Inc.
At ROOMS (Radon Outcomes on Mitigation Solutions) conference (27<sup>th</sup>-28<sup>th</sup> September
2018, Lugano, Switzerland). SUPSI.

Fowler, C. S., Williamson, A. D., Pyle, B. E., Belzer, F. E., Coker, R. N. (1991). Handbook: Subslab depressurization for low-permeability fill material. Design & installation of a home
radon reduction system. US EPA, Washington, DC, USA.

480 Frutos, B. (2009), 'Estudio experimental sobre la efectividad y la viabilidad de distintas
481 soluciones constructivas para reducir la concentración de fas radón en edificaciones'
482 Universidad Politécnica de Madrid, Madrid

Frutos, B., Olaya, M., Santiago, L., Poncela, Q., Sainz, C. (2011). 'Experimental study of effectiveness of four radon mitigation solutions, based on underground depressurization, tested in prototype housing built in a high radon area in Spain', Journal of Environmental

486 Radioactivity, 102(4), 378–385. <u>https://doi.org/10.1016/j.jenvrad.2011.02.006</u>

487 Fuente, M., Rabago, D., Herrera, S., Quindos, L., Fuente, I., Foley, M., Sainz, C. (2018).

488 'Performance of radon monitors in a purpose-built radon chamber'. Journal of Radiological

489 Protection, 38, 1111-1127. <u>https://doi.org/10.1088/1361-6498/aad969</u>

- Fuente, M., Muñoz, E., Sicilia, I., Goggins, J., Hung, L.C., Frutos, B., Foley, M. (2019).
  'Investigation of gas flow through soils and granular fill materials for the optimisation of
  radon soil depressurisation system'. Journal of Environmental Radioactivity, 198, 200-209.
- 493 <u>https://doi.org/10.1016/j.jenvrad.2018.12.024</u>
- 494 Garcia-Tobar, J. (2019). 'Weather-dependent modelling of the indoor radon concentration in
- 495 two dwellings using CONTAM'. Indoor and Built Environment, 0 (0), 1-9.
   496 <u>https://doi.org/10.1177/1420326X19841119</u>
- 497 Hung, L.C., Goggins, J., Fuente, M., Foley, M. (2018a). 'Characterisation of specified granular
- 498 fill material for radon mitigation by soil depressurisation systems', Construction and Building
- 499 Materials, 176, 213-227. <u>https://doi.org/10.1016/j.conbuildmat.2018.04.210</u>
- 500 Hung, L.C., Goggins, J., Fuente, M., Foley, M. (2018b). 'Investigation of sub-slab pressure 501 field extension in specified granular fill materials incorporating a sump-based soil 502 depressurisation system for radon mitigation', Science of the Total Environment, 637–638,
- 503 1081–1097. <u>https://doi.org/10.1016/j.scitotenv.2018.04.401</u>
- Hung, L.C., Goggins, J., Croxford, C., Foley, M. (2019). 'Large-scale experimental investigation
  of specified granular fill materials for radon mitigation by active and passive soil
  depressurisation'. Manuscript submitted for publication.
- Jiranek, M. (2014). 'Sub-slab depressurisation systems used in the Czech Republic and verification of their efficiency'. Radiation Protection Dosimetry, 162(1-2), 64-67. doi:10.1093/rpd/ncu219

Long, S., Fenton, D., Cremin, M., Morgan, A. (2013). 'The effectiveness of radon preventive
and remedial measures in Irish homes', Journal of Radiological Protection, 33,141-149.
doi:10.1088/0952-4746/33/1/141

513 Mentes, G, Eper-Papao, I. (2015). 'Investigation of temperature and barometric pressure 514 variation effects on radon concentration in the Sopronbanfalva Geodynamic Observatory, 515 Hungay'. Journal of Environmental Radioactivity, 149, 64-72. 516 <u>https://doi.org/10.1016/j.jenvrad.2015.07.015</u>

Nero, A.V., Gadgil, A.J., Nazaroff, W.W, Revzan, K.L. (1990). 'Indoor radon and its decay
products: concentrations, causes and control strategies'. Technical report. Lawrence
Berkeley Laboratory. University of California, Berkeley, CA, USA.

Riley, W.J., Gadgil, A.J., Bonnefous, Y.C., Nazaroff, W. (1996). 'The effect of steady winds on radon-222 entry from soil into houses'. Atmospheric Environment, 30, 1167–1176.

522 <u>https://doi.org/10.1016/1352-2310(95)00248-0</u>

523 Schubert, M, Mussolff, A., Weiss, H. (2018). 'Influences of meteorological parameters on 524 indoor radon concentrations (<sup>222</sup>Rn) excluding the effects of forced ventilation and radon 525 exhalation from soil and building materials)'. Journal of Environmental Radioactivity, 198, 526 81-85.

527 Scivyer, C. R. and Jaggs, M.P.R. A BRE guide to radon remedial measures in existing 528 dwellings. Dwellings with cellars and basements. BRE, 1998.

World Health Organization, Handbook on Indoor Radon. A public health perspective, WHO
Press, Geneva, Switzerland, 2009.

- 531 WHO. https://www.who.int/news-room/fact-sheets/detail/radon-and-health, (Accessed 04
- 532 May 2019). Updated 30 June 2016.
- 533 World Health Organization, WHO Housing and Health Guidelines, 2018.

Phase	Description	Dates				
1	Closed period	25/06/2018 - 26/07/2018				
2	Passive SD	26/07/2018 – end of August				
No meas	urements (issues related with t	he pressure sensors)				
3	Closed period	10/10/2018 - 13/11/2018				
4	Active SD ( $v_{ext}$ = 0 – 4 m/s)	13/11/2018 – 16/11/2018				
No meas	No measurements (issues related to power supply in the house)					
5	Closed period	13/12/2018 – 19/02/2019				
6	Active SD ( $v_{ext}$ = 1.5 m/s)	19/02/2019 - 06/03/2019				
7	Closed period	06/03/2019 – 14/03/2019				
8	Active SD ( $v_{ext}$ = 2 m/s)	14/03/2019 - 02/04/2019				
9	Closed period	02/04/2019 - 30/04/2019				

1 Table 1. Summary of testing phases at the pilot house.

2

Table 2. Radon concentration C<sub>Rn</sub> found in the basement and ground floor for the SD testing
phases indicated and radon reduction, respect to the average radon levels for the closed
periods.

	$C_{\rm Rn}$ (Bq/m <sup>3</sup> )		Radon reduction	
	Basement	Ground Floor	Basement	Ground Floor
Average closed	54625	26421		
Phase 2: passive SD	7417	-	86%	-

Phase 4: active SD	662	378	99%	99%
(v <sub>ext</sub> = 0 - 4 m/s)	002	520	5570	5576
Phase 6: active SD	3326	3689	94%	86%
(v <sub>ext</sub> = 1.5 m/s)	5520	3009	5470	0070
Phase 8: active SD	3701	2279	93%	91%
$(v_{\rm ext} = 2  {\rm m/s})$				51/0



- 2 Figure 1. Map of Spain and plan of the mining facilities indicating the location of the pilot
- 3 house and a recent picture of the building.



- Figure 2. Section view of the house and plan of the basement after installation of mitigation
- 6 measures, modified from Frutos et al. (2011).



Figure 3. Schema of the pilot house for the closed periods, active SD and passive SD testing
phases. Section view of the experimental house shows the pressure sensors system in the
basement (same for all phases), the mechanical fan installed on the central pipe (for the

active SD performance) and the top of the exhaust pipe in the house rooftop, with a cap, a
rotating cowl or opened, depending on the testing phase.



Figure 4. Radon concentration recorded in the basement and ground floor of the pilot
house. The solid line indicates the closed testing periods and the dashed line (shaded areas)
indicates the periods of SD performance.



Figure 5. Radon concentration recorded in the basement and ground floor of the pilot house along with atmospheric variables, a) atmospheric pressure, b) outdoor temperature and c) wind velocity, for different time periods while the house was closed. Pearson's correlation coefficient between radon concentration in the basement and the corresponding atmospheric variable is indicated.



Figure 6. Hourly averaged pressure induced under the slab at the sump and the different measurement points with distances indicated from the central pipe along with hourly averaged wind velocity recorded at the site.



Figure 7. Pressure drop with distance against pressure induced at the sump. Dots represent the experimental data obtained from pressure records at distances d= 1, 2 and 2.4 m from

the sump, both for active and passive SD testing phases. The dashed line is the linear trend obtained from all the experimental data, with a coefficient of determination  $R^2$ =0.95.



Figure 8. (a) Pressure induced under the slab against the extraction velocity of the mechanical fan for the different measurement points at different distances from the suction point. (b) Pressure induced at the sump under the slab against the wind velocity.



6

Figure 9. Extraction airflow through the central exhaust pipe as function of the pressure difference generated between the aggregate layer under the slab and the inhabited volume of the basement. Dots represent the experimental data for the active SD (purple) and passive SD (green), the dashed lines are the trends obtained from the experimental data and the solid lines represent the law relating extraction airflow with depressurisation for active and passive SD from Abdelouhab et al. (2010).



Figure 10. Pressure induced under the slab against extraction airflow through the central exhaust pipe, along with some results from the work of Hung et al. (2019) for the pressure difference obtained through different layers of T2 Perm aggregate material as function of the extraction airflow. Dots represent the experimental data for the active SD in purple and passive SD in green, and the results from Hung et al. (2019) in grey. The dashed lines are the trends obtained for the experimental data.